

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Jim Doyle, Governor Richard J. Leinenkugel, Secretary

March 4, 2009

WIESER CONCRETE PRODUCTS, INC. MARK WIESER 2815 RILEY ROAD PORTAGE WI 53901

Re: Description: SEWAGE TREATMENT APPARATUS (see also SEWAGE TANKS; STA-

TANK/CONTAINER)

Manufacturer: WIESER CONCRETE PRODUCTS, INC.

Product Name: MICROFAST® 1.5 OR HIGH STRENGTH FAST® 1.5

Model Number(s): W2000 BIO

[MAX. 1500 GPD DWF; 42.92 GAL./IN.]

Product File No: 20090088

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2014.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the
  department's stamp of approval. The plans and specifications must be open to inspection by an authorized
  representative of the department.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.

This approval supersedes the approval issued on 4/26/2004under product file number 20040217.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST

Engineering Consultant--Plumbing Product Reviewer

Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658

Phone: 608-266-0955; Fax: 608-283-7456 E-mail: Jean.MacCubbin@wisconsin.gov

SBD-10564-E (N.10/97) File Ref: 09008802.DOC